

Document I.D.: _____

Product Pt/No.: _____

Serial Number(s): _____

Date: _____



Precision Engineering

Norgren Limited

Cross Chancellor Street, Leeds LS6 2RT

West Yorkshire, United Kingdom

Tel: +44 (0)113 2457587

www.imi-precision.com

UK-LeedsSales@imi-precision.com

DECLARATION OF CONFORMITY

IMI Precision Engineering - Norgren Ltd. declares under our sole responsibility that the product(s) listed below complies with the relevant provisions of Directive 2014/34/EU and Directive 2014/30/EU.

Manufactured by: IMI Precision Engineering - Norgren Ltd.
Cross Chancellor Street, Leeds, LS6 2RT, UK.

ATEX DIRECTIVE 2014/34/EU	EMC DIRECTIVE 2014/30/EU
Product(s): Type 422 I/P Converter Pt/No. range: AC301xxx x = dependent on product variant	Product(s): Type 422 I/P Converter Pt/No. range: AC301xxx Pt/No. range: ACxxxx or ACxxxxx. x = dependent on product variant
Notified Body: CSA Group Netherlands B.V. Utrechtseweg 310 (B42), 6812AR ARNHEM, Netherlands. Notified Body number: 2813	
Production Quality Assurance Notification: Sira 02ATEX M189	
Conformity has been demonstrated with reference to the following documentation: EC Type Examination Certificate: Sira 03ATEX2007X (Intrinsically Safe)	
Compliance with the Essential Health & Safety Requirements has been assessed by reference to the following standards: EN 60079-0:2012 / A11:2013 EN 60079-11:2012 EN 60079-26:2007	Representative sample(s) of the Type 422 I/P Converter have been tested and evaluated in accordance to the following Standards: EN 61000-6-4:2007 + A1:2011 Electromagnetic Compatibility (EMC) Part 6-4: Generic Standards – Emission for Industrial Environments EN 61000-6-2:2005 Electromagnetic Compatibility (EMC) Part 6-2: Generic Standards - Immunity for Industrial Environments to demonstrate compliance with the Directive 2014/30/EU.
NOTES: EN 60079-26:2007 is no longer harmonised. The requirements of this standard have been checked against IEC 60079-26:2014 Edition 3.0 (Document ref. 2017-031a) and there were no major changes affecting the latest technical knowledge for the product listed so the assessment according to EN 60079-26:2007 continues to represent "State of the Art".	NOTES:

Name: Marc Robertson

Signed: 

Position: Plant Director

Date: 10/10/19

Document No. 2005-038f
Date 01 Aug 2003
Re-issued 04 Oct 2019