

# Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

<b>Manufacturer</b>	<b>IMI International s.r.o. – NORGREN CZ</b>
<b>Address</b>	Evropská 852, Modrice, 664 42, Czech Republic
<b>Type</b>	Switches - Pressure
<b>Description</b>	Pneumatic and hydraulic pressure switches Types Pneumatic pressure switch types: 0880241, 0880341, 0880441, 0880641  Hydraulic pressure switch types: 0882141, 0882241, 0882341
<b>Trade Name</b>	Series 18 D
<b>Application</b>	Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2, ENV3 and ENV4 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1- 1996
<b>Specified Standard</b>	en 5.11.008; 6/2015 en 5.11.108; 6/2015 Series 18 D Datasheets



**Jochen Koerner**

Senior Specialist to Lloyd's Register EMEA  
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

---

## Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document HPC/ETS 41460-21 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

---

## **Appendix**

**PLACE OF PRODUCTION** IMI International s.r.o. – NORGREN CZ, Evropska 861, Modrice, CZ

**Technical data**

**Series 18D**

Maximum contact load: 250 V AC, 0,1 A

Temperature of medium: 0°C to 70° C

